




Hazardous Area Specifications

	Intrinsically Safe (4-20 mA Only)	Division 2																				
<p>Factory Mutual (FM) Approvals</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: left; padding: 2px;">Entity Parameters</th> </tr> <tr> <td style="padding: 2px;">V_{max}¹ = 30 VDC</td> <td style="padding: 2px;">C_i³ = 0 μ F</td> </tr> <tr> <td style="padding: 2px;">I_{max}² = 200 mA</td> <td style="padding: 2px;">L_i⁴ = 0 mH</td> </tr> <tr> <td style="padding: 2px;">¹V_{max} = Max. Voltage</td> <td style="padding: 2px;">³C_i = Capacitance</td> </tr> <tr> <td style="padding: 2px;">²I_{max} = Max. Current</td> <td style="padding: 2px;">⁴L_i = Inductance</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: left; padding: 2px;">Non-Incendive Field Wiring Parameters</th> </tr> <tr> <td style="padding: 2px;">V_{max}¹ = 30 VDC</td> <td style="padding: 2px;">C_i³ = 0 μ F</td> </tr> <tr> <td style="padding: 2px;"></td> <td style="padding: 2px;">L_i⁴ = 0 mH</td> </tr> <tr> <td style="padding: 2px;">¹V_{max} = Max. Voltage</td> <td style="padding: 2px;">³C_i = Capacitance</td> </tr> <tr> <td style="padding: 2px;"></td> <td style="padding: 2px;">⁴L_i = Inductance</td> </tr> </table>	Entity Parameters		V _{max} ¹ = 30 VDC	C _i ³ = 0 μ F	I _{max} ² = 200 mA	L _i ⁴ = 0 mH	¹ V _{max} = Max. Voltage	³ C _i = Capacitance	² I _{max} = Max. Current	⁴ L _i = Inductance	Non-Incendive Field Wiring Parameters		V _{max} ¹ = 30 VDC	C _i ³ = 0 μ F		L _i ⁴ = 0 mH	¹ V _{max} = Max. Voltage	³ C _i = Capacitance		⁴ L _i = Inductance	<p>TDFI7800/7801, TAFI7800/7801 Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Class III, Division 1, Fibers; NEMA 4X Enclosure; Temperature Code T4, T_{amb} = -20 °C to 65 °C</p> <hr/> <p>TTFI7800/7801, TRFI7800/7801 Class I, Division 1, Groups C and D; Temperature Code T4, T_{amb} = -20 °C to 65 °C</p> <hr/> <p>TDCI7800/7801, TACI7800/7801 Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Type 4 Enclosure; Rated 4-20 mA, 30 VDC maximum; Temperature Code T6.</p> <hr/> <p>TTCI7800/7801, TRCI7800/7801 Class I, Division 1, Groups C and D; Rated 4-20 mA, 30VDC maximum; Temperature Code T6.</p>	<p>TDFI7800/7801, TAFI7800/7801, TDFN7800/7801, TAFN7800/7801 Class I, Division 2, Groups A, B, C and D; Suitable for Class II, Division 2, Groups F and G; Class III, Division 2; NEMA 4X Enclosure; Non-Incendive 4-20 mA, voltage input units ; Temperature Code T4.</p> <hr/> <p>TTFI7800/7801, TRFI7800/7801, TTFN7800/7801, TRFN7800/7801 Class I, Division 2, Groups A, B, C and D; Non-Incendive 4-20 mA, voltage input units; Temperature Code T4.</p> <hr/> <p>TDCI7800/7801, TTCI7800/7801, TRCI7800/7801 Class I, Division 2, Groups A, B, C and D; Rated 4-20 mA, 30 VDC maximum; Temperature Code T6.</p> <hr/> <p>TACI7800/7801 Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups E, F and G; Type 4 Enclosure; Rated 4-20 mA, 30 VDC maximum; Temperature Code T6.</p>
Entity Parameters																						
V _{max} ¹ = 30 VDC	C _i ³ = 0 μ F																					
I _{max} ² = 200 mA	L _i ⁴ = 0 mH																					
¹ V _{max} = Max. Voltage	³ C _i = Capacitance																					
² I _{max} = Max. Current	⁴ L _i = Inductance																					
Non-Incendive Field Wiring Parameters																						
V _{max} ¹ = 30 VDC	C _i ³ = 0 μ F																					
	L _i ⁴ = 0 mH																					
¹ V _{max} = Max. Voltage	³ C _i = Capacitance																					
	⁴ L _i = Inductance																					
<p>ATEX Approvals</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: left; padding: 2px;">Transducer Parameters</th> </tr> <tr> <td style="padding: 2px;">U_{max}¹ = 28 V</td> <td style="padding: 2px;">P_i³ = 0.7 W</td> </tr> <tr> <td style="padding: 2px;">I_{max}² = 100 mA</td> <td style="padding: 2px;">C_i⁴ = 0</td> </tr> <tr> <td style="padding: 2px;"></td> <td style="padding: 2px;">L_i⁵ = 0</td> </tr> <tr> <td style="padding: 2px;">¹U_{max} = Max. Voltage</td> <td style="padding: 2px;">³P_i = Max. Power</td> </tr> <tr> <td style="padding: 2px;">²I_{max} = Max. Current</td> <td style="padding: 2px;">⁴C_i = Capacitance</td> </tr> <tr> <td style="padding: 2px;"></td> <td style="padding: 2px;">⁵L_i = Inductance</td> </tr> </table>	Transducer Parameters		U _{max} ¹ = 28 V	P _i ³ = 0.7 W	I _{max} ² = 100 mA	C _i ⁴ = 0		L _i ⁵ = 0	¹ U _{max} = Max. Voltage	³ P _i = Max. Power	² I _{max} = Max. Current	⁴ C _i = Capacitance		⁵ L _i = Inductance	<p>TAEI7800/7801, TDEI7800/7801 EEx ia IIB, T4, T_{amb} = -20 °C to 72 °C ⚠ II 1G (T4), II 1D (T85 °C) IP65 Enclosure</p> <hr/> <p>TTEI7800/7801, TREI7800/7801 EEx ia IIB, T4, T_{amb} = -20 °C to 72 °C ⚠ II 1G (T4)</p>							
Transducer Parameters																						
U _{max} ¹ = 28 V	P _i ³ = 0.7 W																					
I _{max} ² = 100 mA	C _i ⁴ = 0																					
	L _i ⁵ = 0																					
¹ U _{max} = Max. Voltage	³ P _i = Max. Power																					
² I _{max} = Max. Current	⁴ C _i = Capacitance																					
	⁵ L _i = Inductance																					
<p>IECEx Approvals</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: left; padding: 2px;">Transducer Parameters</th> </tr> <tr> <td style="padding: 2px;">U_j¹ = 28 V</td> <td style="padding: 2px;">P_i³ = 0.7 W</td> </tr> <tr> <td style="padding: 2px;">I_{max}² = 100 mA</td> <td style="padding: 2px;">C_i⁴ = 12 nF</td> </tr> <tr> <td style="padding: 2px;"></td> <td style="padding: 2px;">L_i⁵ = 0</td> </tr> <tr> <td style="padding: 2px;">¹U_{max} = Max. Voltage</td> <td style="padding: 2px;">³P_i = Max. Power</td> </tr> <tr> <td style="padding: 2px;">²I_{max} = Max. Current</td> <td style="padding: 2px;">⁴C_i = Capacitance</td> </tr> <tr> <td style="padding: 2px;"></td> <td style="padding: 2px;">⁵L_i = Inductance</td> </tr> </table>	Transducer Parameters		U _j ¹ = 28 V	P _i ³ = 0.7 W	I _{max} ² = 100 mA	C _i ⁴ = 12 nF		L _i ⁵ = 0	¹ U _{max} = Max. Voltage	³ P _i = Max. Power	² I _{max} = Max. Current	⁴ C _i = Capacitance		⁵ L _i = Inductance	<p>TAEI7800/7801, TDEI7800/7801 EEx ib IIB, T4, Gb T_a = -40 °C to 64 °C Ex ib III T135 °C Db T_a = -40 °C to 55 °C IECEx SIR 08.130 IP65 Enclosure</p> <hr/> <p>TTEI7800/7801, TREI7800/7801 Ex ib IIB, T4, Gb T_a = -40 °C to 64 °C IECEx SIR 08.0130</p>							
Transducer Parameters																						
U _j ¹ = 28 V	P _i ³ = 0.7 W																					
I _{max} ² = 100 mA	C _i ⁴ = 12 nF																					
	L _i ⁵ = 0																					
¹ U _{max} = Max. Voltage	³ P _i = Max. Power																					
² I _{max} = Max. Current	⁴ C _i = Capacitance																					
	⁵ L _i = Inductance																					



Model TXI7800/7801 Explosion-Proof Transducer

Hazardous Area Classifications

	Explosion-Proof	Intrinsically Safe															
Factory Mutual (FM) Approvals  	Air as supply pressure media Class I, Division 1, Groups B, C and D; Class II, Division 1, Groups E, F and G; Class III, Division 1, Fibers; Class I, Division 2, Groups A, B, C and D; NEMA 4X Enclosure; Max. Ambient 65°C; Temperature Code T5.	Air as supply pressure media Class I, Division I, Groups C and D; Class II, Division 1, Groups E, F and G; Class III, Division 1; Fibers; NEMA 4X Enclosure; Max. Ambient 65°C; Temperature Code T4.															
	Group D gases, including Natural Gas as supply pressure media Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups E, F and G.	<table border="1"> <thead> <tr> <th colspan="2">Entity Parameters</th> </tr> </thead> <tbody> <tr> <td>$V_{max}^1 = 30$ VDC</td> <td>$C_i^3 = 0$ μ F</td> </tr> <tr> <td>$I_{max}^2 = 200$ mA</td> <td>$L_i^4 = 0$ mH</td> </tr> <tr> <td>¹V_{max} = Max. Voltage</td> <td>³C_i = Capacitance</td> </tr> <tr> <td>²I_{max} = Max. Current</td> <td>⁴L_i = Inductance</td> </tr> </tbody> </table>	Entity Parameters		$V_{max}^1 = 30$ VDC	$C_i^3 = 0$ μ F	$I_{max}^2 = 200$ mA	$L_i^4 = 0$ mH	¹ V_{max} = Max. Voltage	³ C_i = Capacitance	² I_{max} = Max. Current	⁴ L_i = Inductance					
Entity Parameters																	
$V_{max}^1 = 30$ VDC	$C_i^3 = 0$ μ F																
$I_{max}^2 = 200$ mA	$L_i^4 = 0$ mH																
¹ V_{max} = Max. Voltage	³ C_i = Capacitance																
² I_{max} = Max. Current	⁴ L_i = Inductance																
Canadian Standards Association (CSA) Approvals 	Air as supply pressure media Class I, Division 1, Groups B, C and D; Class II, Division 1, Groups E, F and G; Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups E, F and G. Type 4X Enclosure; Temperature Code T5; Max. Ambient 65°C.	Air as supply pressure media Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Type 4X Enclosure; Temperature Code T4; Rated 4-20 mA, 30 VDC maximum.															
	Group D gases, including Natural Gas as supply pressure media Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Class I, Division 2, Groups A, B, C and D. Class II, Division 2, Groups E, F and G.	<table border="1"> <thead> <tr> <th colspan="2">Approvals are valid when connected through a Shunt Zener Diode Safety Barrier meeting the following parametric requirements:</th> </tr> </thead> <tbody> <tr> <td>System Type 1:</td> <td>Single Channel Polarized Rated: 28.5V Max. 300 Ohm Min.</td> </tr> <tr> <td>System Type 2:</td> <td>Dual Channel Polarized Rated 28.5V Max. 300 Ohm Min. and 28V Diode return per channel</td> </tr> <tr> <td>System Type 3:</td> <td>Dual Channel Polarized Rated: 28.5V Max. 300 Ohm Min. and 10V Max. 50 Ohm Min.</td> </tr> </tbody> </table>	Approvals are valid when connected through a Shunt Zener Diode Safety Barrier meeting the following parametric requirements:		System Type 1:	Single Channel Polarized Rated: 28.5V Max. 300 Ohm Min.	System Type 2:	Dual Channel Polarized Rated 28.5V Max. 300 Ohm Min. and 28V Diode return per channel	System Type 3:	Dual Channel Polarized Rated: 28.5V Max. 300 Ohm Min. and 10V Max. 50 Ohm Min.							
Approvals are valid when connected through a Shunt Zener Diode Safety Barrier meeting the following parametric requirements:																	
System Type 1:	Single Channel Polarized Rated: 28.5V Max. 300 Ohm Min.																
System Type 2:	Dual Channel Polarized Rated 28.5V Max. 300 Ohm Min. and 28V Diode return per channel																
System Type 3:	Dual Channel Polarized Rated: 28.5V Max. 300 Ohm Min. and 10V Max. 50 Ohm Min.																
	Flame-Proof	Intrinsically Safe															
Explosive Atmospheres Directive (ATEX) Approvals*	Air as supply pressure media ⓧ II 2 GD EEx d IIB + H ₂ , T5 (-20°C to +65°C) Ambient; IP65 Enclosure.	Air as supply pressure media ⓧ II 1 G (T4) II1D (T 85°C) EEx ia IIB, T4 (-20°C to +72°C) Ambient; IP65 Enclosure.															
	Group IIA gases, including Natural Gas as supply pressure media ⓧ II 2 GD EEx d IIB, T5 (-20°C to +65°C) Ambient; IP65 Enclosure.																
Standards Australia (SAA) Approvals*	Air as supply pressure media Ex d IIB + H ₂ , T5 (-20°C to +65°C) Ambient; IP65 Enclosure.	Air as supply pressure media Ex ia IIB, T4 (-20°C to +72°C) Ambient.															
	<table border="1"> <thead> <tr> <th colspan="3">Transducer Parameters</th> </tr> </thead> <tbody> <tr> <td>$U_{max}^1 = 28$ V</td> <td>$P_i^3 = 0.7$ W</td> <td>$L_i^5 = 0$</td> </tr> <tr> <td>$I_{max}^2 = 100$ mA</td> <td>$C_i^4 = 0$</td> <td></td> </tr> <tr> <td>¹U_{max} = Max. Voltage</td> <td>³P_i = Max. Power</td> <td>⁵L_i = Inductance</td> </tr> <tr> <td>²I_{max} = Max. Current</td> <td>⁴C_i = Capacitance</td> <td></td> </tr> </tbody> </table>	Transducer Parameters			$U_{max}^1 = 28$ V	$P_i^3 = 0.7$ W	$L_i^5 = 0$	$I_{max}^2 = 100$ mA	$C_i^4 = 0$		¹ U_{max} = Max. Voltage	³ P_i = Max. Power	⁵ L_i = Inductance	² I_{max} = Max. Current	⁴ C_i = Capacitance		
Transducer Parameters																	
$U_{max}^1 = 28$ V	$P_i^3 = 0.7$ W	$L_i^5 = 0$															
$I_{max}^2 = 100$ mA	$C_i^4 = 0$																
¹ U_{max} = Max. Voltage	³ P_i = Max. Power	⁵ L_i = Inductance															
² I_{max} = Max. Current	⁴ C_i = Capacitance																
IECEx Approvals		<table border="1"> <thead> <tr> <th colspan="3">Transducer Parameters</th> </tr> </thead> <tbody> <tr> <td>$U_i^1 = 28$ V</td> <td>$P_i^3 = 0.7$ W</td> <td>$L_i^5 = 0$</td> </tr> <tr> <td>$I_i^2 = 100$ mA</td> <td>$C_i^4 = 0$</td> <td></td> </tr> <tr> <td>¹U_i = Max. Voltage</td> <td>³P_i = Max. Power</td> <td>⁵L_i = Inductance</td> </tr> <tr> <td>²I_i = Max. Current</td> <td>⁴C_i = Capacitance</td> <td></td> </tr> </tbody> </table> <p> TEXI7800/01 (Ta -40°C to 64°C) Ex ia IIB T4 Gb Ex ib IIIB T74°C Db IECEx SIR 09.0003 IP65 Enclosure </p>	Transducer Parameters			$U_i^1 = 28$ V	$P_i^3 = 0.7$ W	$L_i^5 = 0$	$I_i^2 = 100$ mA	$C_i^4 = 0$		¹ U_i = Max. Voltage	³ P_i = Max. Power	⁵ L_i = Inductance	² I_i = Max. Current	⁴ C_i = Capacitance	
Transducer Parameters																	
$U_i^1 = 28$ V	$P_i^3 = 0.7$ W	$L_i^5 = 0$															
$I_i^2 = 100$ mA	$C_i^4 = 0$																
¹ U_i = Max. Voltage	³ P_i = Max. Power	⁵ L_i = Inductance															
² I_i = Max. Current	⁴ C_i = Capacitance																